



125 Valley Court
Oak Ridge, TN 37830
(865) 482-7762 Fax (865) 483-6995
www.MEandT.com
Info@MEandT.com
patrickw@meandt.com
ISO/IEC 17025:1999



Mechanical Test Report: Tensile Properties

Contact: Glenn Myrick

NCI BUILDING SYSTEMS

422 Kirby Drive

Lexington, TN 38351

Report Date: 10/05/07

ME&T#: 41490 & 41491

Quote#: Verbal

P.O.#: 1354209

Revision 1: 10/05/07

Date Sample Received: 09/24/07

Mill: NUCOR

Specification: ASTM A572 Grade 50

Alloy Content: Type 2

Universal Tester: 228

Test Procedure: MPT-10.0, ASTM A370

Operator: W.J. Werner

Test Date: 10/04/07

TEST RESULTS

	<u>ME&T#</u> <u>41490</u>	<u>ME&T</u> <u>41491</u>
Area (in ²):	<u>0.122</u>	<u>0.122</u>
Ultimate Tensile Strength (psi):	<u>62954</u>	<u>62616</u>
Yield Strength (psi):	<u>45968</u>	<u>48288</u>
Elongation (%):	<u>36.1</u>	<u>33.2</u>
Heat:	<u>275434</u>	<u>275434</u>
Coil:	<u>275434-4B</u>	<u>275434-4B</u>
Thickness (in):	<u>.2415</u>	<u>.2415</u>
Alloy Content:	<u>Type 2</u>	<u>Type 2</u>
CMTR Conformance (Tensile) ASTM A1018:	<u>Yes</u>	<u>Yes</u>
CMTR Conformance (Composition) ASTM A572 Grade 50*:	<u>Yes</u>	<u>Yes</u>
Tensile Conformance to ASTM A572 Grade 50:	<u>No</u>	<u>No</u>

Materials Engineering & Testing certifies results as indicated.

Sincerely,

Patrick Werner
President, **ME&T**